



State Fire Marshal's Office

PO Box 12107 | Austin, TX 78711 | 512-676-6800 | tdi.texas.gov/fire

5/25/2022

Chief Bill Evans
1700 Lake Bardwell Dr
Ennis, TX 75119
bevans@ennistx.gov

Place Code: 13928
Community: Ennis

Dear Chief Bill Evans:

Insurance Services Office (ISO) has submitted a recommendation concerning your community's Public Protection Classification (PPC). Currently, the community's Public Protection Classification is a class 2/10.

Insurance Services Office is recommending the Public Protection Classification be changed to a split class 02/2X, with an effective date of 10/1/2022. The recommendation is based on a review of your community performed on 12/13/2021 and does include application of the Texas Exception to the Fire Suppression Rating Schedule.

With a split class, all class-rated properties located within 1000 feet of a fire hydrant or water supply suction point and within 5 miles of a fire station will use Class 02. All class-rated properties located farther than 1000 feet of a fire hydrant or water supply suction point and within 5 miles of a fire station will use Class 2X.

Public Protection Classifications range from 1 (superior) to 10 (does not meet minimum criteria).

We have reviewed the information provided and believe it is enough to grant approval. The Insurance Services Office will be notified of our approval of their recommendation and the effective date.

If you have any questions regarding this change, I may be reached at the address indicated above or by email to PPCOversight@tdi.texas.gov.

Please make sure all community officials and residents within your district are notified of the new Public Protection Classification rating for your community, and the effective date.

We would like to find out how you feel about the Public Protection Classification (PPC) process and the Insurance Services Office (ISO) inspection services, by your participation in a brief customer satisfaction survey. Please click [here](#) to complete our survey.

We thank you for your time.

Sincerely,




Joel Duke
PPC Oversight Officer
PPCOversight@tdi.texas.gov

TEXAS STATE FIRE MARSHAL

Approved

Disapproved

Signature:  _____ Date: _____